TEST REPORT

Report No:202309A0371

Entrusted by: Duanguan Qunan Plastic Industrial Co.,Ltd

Sample name: SGPIonoplast interlayer

Test Type: Entrustment Test

China Testing & Certification International Group Co., Ltd

ctc 国检集团

China Testing & Certification International Group Co., Ltd

Test Report

Report No：202309A0371

Sample Name	SGPIonoplast interlayer	Test Type	Entrustment Test
Entrusted by	Duanguan Qunan Plastic Industrial Co.,Ltd	Trademark	————
Manufacturer	Duanguan Qunan Plastic Industrial Co.,Ltd	Sample Status	Samples meet the test requirments
Reception Date	November 29,2023	Sample Quantity	3 Pieces
Manufacture Date/Batch No.	————	Model/Size	300mm×300mm×11.14mm
Test Method	Shown on the data sheet	Test date	December 6-7,2023
Criterion	ASTMC1914-21《Laminated glass baking and boiling experiments》		
Test Projuct	Baking experiments		
Conclusion	*After testing, the test results of the items inspected by the samples met the requirements of ASTMC1914-21 standard. The test results are shown on page 2* Date of issue：December 21,2023		

Remark：

1、The following information is provided and responsible for by the entrusting unit.

Specimen structure：5mm colorless transparent glass (tin 2#) + 1.14mm colorless SGP ionic film + (tin 3#) 5mm colorless glass

Experiment method：Place in a 100 degree oven for 16 hours

The sample has no coating, no plug-in and no color glaze.

2、This report is not an accreditation report. Our laboratory does not guarantee the effectiveness when the test results are used as evidence for the activities including but not limited on judicial, arbitration and administrative law enforcement.

Approved：　　Checked by：　　Compiled by：

Laboratory address:No.1 Guanzhuang Dongli,Chaoyang District, Beijing,100024,P.R.China
Tel:+86-10-51167363

ctc 国检集团

China Testing & Certification International Group Co., Ltd

TestReport

Report No：202309A0371

Test Item	Baking experiments
Test Method	ASTMC1914-21《Laminated glass baking and boiling experiments》
Criterion	ASTMC1914-21 requests； Glass can produce cracks, if there is no bubble beyond the edge of the sample and the area of the crack 12 mm, the sample is "qualified"; If bubbles occur in the area of 12mm beyond the edge and crack of the sample, the sample is "unqualified". If discoloration occurs in any part of the sample after the test, the colour and extent shall be indicated in the report and the sample shall be considered "acceptable". If any one of the three samples in the sample group fails, the sample in the sample group is "failed". If cracks in some samples affect the judgment results, a new sample should be used for testing.

Test Result

Sample No.	The state of the sample after thr test	Monolithic conclusion
1	No cracks appeared in the sample, and no bubbles were generated in the area 12mm beyond the edge of the sample. No discoloration occurred in the sample	Pass
2	No cracks appeared in the sample, and no bubbles were generated in the area 12mm beyond the edge of the sample. No discoloration occurred in the sample.	Pass
3	No cracks appeared in the sample, and no bubbles were generated in the area 12mm beyond the edge of the sample. No discoloration occurred in the sample.	Pass
Item Conclusion	Pass	
Remark	1.Test address:Guanzhuang; 2、Main test equipment：J-32DHG-9240Aelectrothermal blowing dry box.	

Checked by:

End of the report

Laboratory address:No.1 Guanzhuang Dongli,Chaoyang District, Beijing,100024,P.R.China
Tel:+86-10-51167363

ctc 国检集团

National inspection Group profile

National Inspection Holding Group Co., LTD. (Chinese abbreviation CTC, English abbreviation CTC, stock code 603060) has developed into a large-scale, comprehensive and third-party inspection and certification service organization in the field of building materials and construction engineering in China. As the first A-share "China" prefix, set inspection and certification as one of the listed companies, branches all over the country, and under the jurisdiction of more than 30 national and industry-level inspection and testing laboratories, It can provide comprehensive solutions for quality, safety, environmental protection, green and energy saving for building materials production enterprises, construction engineering, decoration engineering, railway and rail transit engineering, municipal engineering, power engineering, industrial kiln, renewable resources, new energy, home life and other customers.

China National Testing Holding Group Co., Ltd. has always driven the development of enterprises with "scientific and technological innovation", adhering to the core concept of "fairness and service to society", enhancing the brand value of customers, escorting the sustainable development of the industry, and contributing to the realization of the national initiative of "rejuvenating the country with quality" and "The Belt and Road"!

More details can be found on the company website：http://www.ctc.ac.cn/